Tulare Local Healthcare District dba Tulare Regional Medical Center

Agenda Item

Board Meeting Date: June 26, 2019

Title to Appear on Agenda:

Discussion and Action to Approve the following Capital Improvement Project(s):

b. NPC-2 Emergency Lighting Revision

Brief Description:

Late 2018 the District requested an alternate solution be researched that would still comply with the NPC-2 requirements for exit lights and emergency exit signage throughout the entire hospital.

Architectural and Electrical Engineering has a viable option to add exit lighting, electrical circuits and exiting plans to be installed in all corridors throughout entire hospital as part of the NPC 2 egress exiting plan.

There was a Howe Electric estimate dated June 10, 2019 in the amount of \$342,135 to provide emergency lighting fixtures which was approved at the Special Board Meeting held June 11, 2109. This new revised estimate dated June 19, 2019 in the amount of \$389,142 incorporates backup batteries and associated installation labor to provide required time of operation for emergency egress.

Difference in cost of \$47,007 is comprised of 76 batteries at approximately \$350 each (plus tax and markup), and installation cost of approximately 1 hour per battery at \$105/hour.

Background and Details:

NPC 2 required the following systems to be braced or anchored in accordance with Part 2 Title 24 of the CBC:

- Communication systems
- Emergency Power Supply
- Bulk Medical Gas Systems
- Fire Alarm Systems and
- Emergency corridor Lighting
- Exit lights & signs for the means of egress

The project would be phased accordingly to keep exit passageways open and compliant for means of egress during construction.

Exhibits:

See Attached Proposals from Howe Electrical

Recommended Action:

District to Approve (Howe Electrical) proposal fee of \$389,142 to proceed with the NPC-2 project. Our goal is to be OSHPD NPC-2 compliant by the end of November 2019 and then File for NPC-3 Extension that will be affective until 2030.